

OSAN AIR BASE DRINKING WATER CONSUMER CONFIDENCE REPORT 2025 (Covering Calendar Year 2024)

이 보고서에는 귀하의 식수에 대한 중요한 내용이 실려있습니다. 그러므로 이 보고서를 이해할 수 있는 사람한테 번역해 달라고 부탁드립니다. 보고서에 대한 질문은 생물환경공학과 784-2623 로 문의 하시기 바랍니다.

This consumer confidence report provides the 2024 drinking water quality information for Osan Air Base. This report is based on the data collected, assessed and documented by the Bioenvironmental Engineering (BE) Flight of the 51st Operational Medical Readiness Squadron. It also includes information on how the 51st Civil Engineer Squadron operates and maintains the drinking water system. Please review this report for your information. If you have any questions, please call the Bioenvironmental Engineering Flight at 784-2623.

Sampling To Ensure Your Water Quality

Bioenvironmental Engineering performs water monitoring throughout the year and ensures that your drinking water is the same quality as in the United States. In CY 2024, your tap water met all the quality standards in the Safe Drinking Water Act and the United States Forces Korea Environmental Governing Standards (KEGS) for drinking water.

Drinking Water Contaminants and Your Health

Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it collects contaminants such as naturally occurring minerals, naturally occurring radioactive material or substances from human or animal activities. The contaminants that may be present in any water source include:

- Microbial contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants - such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides - may come from a variety of sources such as agriculture, storm water runoff, and residences.
- Organic chemical contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants - can be naturally occurring or be the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, the Environment Protection Agency (EPA) prescribes regulations that limit the amount of certain contaminants in drinking water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. You can call the EPA Safe Drinking Water Hotline (1-800-426-4791) for more information about contaminants and potential health effects.

Vulnerable Individuals

Some people may be more susceptible to the effects of contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be at greater risk of infections. These people should seek advice about drinking water from their health care providers. The EPA and the Centers for Disease Control provide guidelines to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants. These guidelines are available from the Safe Drinking Water Hotline (1-800-426-4791).

Osan Air Base Water Sources

The primary water source for Osan Air Base is the Han River upstream from Seoul. A collection point outside of Seoul pumps the water to the Sungnam Municipal Water Treatment Plant (WTP) before the WTP supplies the treated water to the base. This treatment includes settling, chemical mixing with powdered activated carbon, flocculation, sedimentation, filtration, and chlorination. The WTP also mixes aluminum sulfate and lime during the summer months to aid in coagulation.

What about the Taste and Color of My Water?

Bioenvironmental Engineering performs weekly representative sampling of the water distribution system; thus, Bioenvironmental Engineering does not routinely sample all buildings on base. It is possible that the plumbing in individual buildings can affect water palatability (i.e., taste). Facility managers and building occupants can often minimize these effects through routine maintenance practices. The Bioenvironmental Engineering Flight (784-2623) is ready to help with any drinking water issue. In the interest of time, please work with your facility manager to conduct routine preventive maintenance on the plumbing in your building before contacting our office.

Some common water palatability issues and corresponding routine maintenance practices are listed below:

1. Rusty pipes: Older metal pipes may rust, resulting in water with reddish-brown color or occasionally small solid particles. This condition is unsightly, but is not a health problem. Rusty pipes affect water most often when water is stagnant, e.g., when water sits in pipes over a long weekend. Facility managers can minimize rusty water by flushing affected pipes (running the water for 30-60 seconds) first thing in the morning, especially on long holiday weekends. **Consumers also can minimize rusty water by flushing their taps until the water appears clear (usually 30 - 60 seconds) before use.**

2. Cloudy/Milky water: Pressure in pipes dissolves gases (usually air or carbon dioxide) in the water. When water comes out of the tap, the pressure is reduced and the dissolved air forms tiny bubbles, giving the water a cloudy appearance. To determine if gas bubbles are causing cloudy water, fill a glass with water and watch it for a minute. If the cloudiness gradually rises to the top of the glass and the water clears, the cloudiness is caused by gas bubbles and is harmless. If the cloudiness persists for more than two minutes or settles to the bottom of the glass, then gas bubbles are not the source of the issue and further investigation is needed to determine the cause of the cloudy/milky water.

3. Dirty water coolers/drinking fountains: Water coolers can become unsightly and unsanitary if not cleaned regularly. Water contains natural minerals that can precipitate near the fountain-head. Since the water cooler surface is often wet, bacteria can grow on the outer surface. This can lead to unpleasant tasting water. Facility managers must maintain cleanliness of the outer surfaces of all water coolers and ensure the water cooler drains are not clogged. In-line filters are sometimes placed on water coolers, but should rarely be necessary. Filters installed on the water coolers must be replaced according to the manufacturer's recommendations.

Frequently Asked Questions about Lead

Where does the lead originate?

Lead is a common metal that can be found throughout our environment in the air, lead-based paint, soil, household dust, and food. It can also be found in certain types of pottery, porcelain, and pewter. Lead is also present in plumbing fixtures made of brass and in solder used by plumbers before 1987. The installation is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components.

Why is lead a health concern?

Lead is a toxic material, known to be harmful to human health if ingested or inhaled. Lead in the body can cause damage to the brain, kidneys, nervous system, and red blood cells. Children, infants, pregnant women, and their unborn children are especially vulnerable to lead. In children, lead has been associated with impaired mental and physical development as well as hearing problems. The harmful effects of lead in the body can be subtle and may occur without any obvious signs of lead poisoning.

Blood levels as low as 10 micrograms per deciliter (ug/dL) are associated with harmful effects on children's learning and behavior. Minimizing sources of exposure to lead can help reduce the number of children with elevated blood lead levels.

Although drinking water is not typically the primary source of lead exposure in children, it can contribute to total lead exposure. Lead can also be introduced into the body through soil and air, which contributes to the total amount of lead exposure. In response, the EPA has set a cumulative blood lead level of less than 10 ug/dL. Therefore, reducing the amount of lead in the drinking water is an important part of reducing a child's overall exposure to lead in the environment.

Why do some faucets have high lead levels?

Lead is unusual among drinking water contaminants because it seldom occurs naturally in water supplies like rivers and lakes. Lead enters drinking water as a result of corrosion or wearing away of materials containing lead used in the facility's plumbing system. Lead materials can be found in lead-based solder used to join copper pipe or in brass and chrome plated brass faucets. In 1986, Congress banned the use of lead solder containing more than 0.2% lead and restricted the lead content of faucets, pipes, and other plumbing materials to 8.0%. When water sits in lead pipes or plumbing containing lead for several hours or more, the lead may dissolve into the water. This means the first water drawn from the tap for the day may contain elevated levels of lead. **As a precaution, consumers are encouraged to flush water from their faucets for 60 seconds before consumption after the faucet has remained unused for 4 or more hours.**

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe drinking water hotline or at www.epa.gov/safewater/lead

Frequently Asked Questions about Copper

How does copper get into my drinking water? The primary sources of copper in drinking water are corrosion of household plumbing systems and erosion of natural deposits. Copper enters the water ("leaches") through contact with the plumbing. Copper leaches into water through corrosion – dissolving or wearing away of metal caused by a chemical reaction between water and your plumbing. Copper can leach into water primarily from pipes, but fixtures, faucets (brass), and fittings can also be a source of copper contaminants. The amount of copper in your water also depends on the types and amounts of minerals in the water, how long the water stays in the pipes, the amount of wear in the pipes, the water's acidity and its temperature. When water sits in copper pipes or plumbing containing copper for several hours or more, the copper may dissolve into the water. This means the first water drawn from the tap for the day may contain elevated levels of copper. **As a precaution, consumers are encouraged to flush water from their faucets for 60 seconds before consumption after the faucet has remained unused for four or more hours.**

Why is copper a health concern?

Some people who drink water containing copper in excess of the recommended level may experience gastrointestinal distress with short-term exposure or may suffer liver or kidney damage with long-term exposure. People with Wilson's Disease are extra sensitive to copper as their bodies are not able to get rid of extra copper easily.

The above information on the health effects of copper is not intended to catalog all possible health effects for copper. Rather, it aims to inform consumers about the possible health effects associated with copper in drinking water relevant to the EPA regulatory standards.

PFAS Contaminant Monitoring

What are per-and polyfluoroalkyl substances and where do they come from?

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS have been used in a variety of industrial and consumer products around the globe, including in the U.S., since the 1940s. PFAS have been used to make coatings and products that are used as oil and water repellents for carpets, clothing, food packaging, and cookware. They are also contained in some fire-fighting foams such as aqueous film-forming foam, or AFFF, used for fighting petroleum fires.

Is there a federal regulation for PFAS in drinking water?¹

Yes. On April 26, 2024, the Environmental Protection Agency (EPA) published a final National Primary Drinking Water Regulation for certain per- and polyfluoroalkyl substances (PFAS) under the Safe Drinking Water Act (SDWA). This rule went into effect on June 25, 2024 with a compliance deadline of April 26, 2029, five years from the date of publication. While the rule requires routine sampling for certain PFAS by no later than 2027, DoD has been sampling drinking water for PFAS compounds at all DoD-owned and operated water systems since 2017. Under the new rule, the following limits, called Maximum Contaminant Levels (MCL), were established, and DoD water systems will need to meet these levels by April 2029.

PFAS	MCL
PFOA	4.0 ppt
PFOS	4.0 ppt
PFHxS	10 ppt
HFPO-DA (GenX)	10 ppt
PFNA	10 ppt
PFBS	n/a
Mixture of two or more: PFHxS, PFNA, HFPO-DA, and PFBS ²	HI of 1 (unitless)

For systems where DoD provides drinking water, the Department is collecting the necessary sampling information and is taking actions to ensure compliance within the required 5-year timeframe. Currently, DoD is finalizing a policy on how to apply the EPA rule OCONUS.

Has Osan AB tested its water for PFAS?

Yes, In April and October 2024 samples were collected from the point of entry to drinking water system. Drinking water testing results were below the MCL for all 6 PFAS compounds covered by the EPA drinking water rule, including PFOA and PFOS. The results detected above the Method Detection Limit (MDL) are provided in Table 7. The water system will be periodically resampled as required by the pending DoD OCONUS drinking water policy to ensure continued compliance.

¹ This language and language may need to change to reflect any promulgated state standards applicable to the installation. Any language changes should be vetted through respective headquarters and public health centers.

² The sampling point is above the HI MCL if the HI exceeds the MCL and if two or more Hazard Index analytes had an observed sample analytical result at or above the PQL in any of the quarterly samples.

Monitored Contaminants

During CY 2024, Bioenvironmental Engineering collected 412 samples to monitor for 112 different contaminants. In addition, the Civil Engineer Squadron monitored chlorine levels daily and Bioenvironmental Engineering monitored chlorine levels weekly. Table 1 lists all of the contaminants monitored in CY 2024 and the required monitoring frequency for each contaminant group.

Table 1. CY 2024 Sample Contaminant Groups & Monitoring Frequencies

Contaminant Group	Number of Contaminants Monitored	Examples	Monitoring Frequency
Biological Contaminants	3	Total coliform, fecal coliform, etc.	Monthly
Inorganic Contaminants	16	Metals, fluoride, etc.	Annually
Nitrate, Nitrite, Total Nitrate/Nitrite	3	--	Quarterly
Volatile Organic Compounds (VOCs)	21	Benzene, toluene, trichloroethylene (TCE), etc.	Annually
Synthetic Organic Compounds (SOCs)	33	Pesticides, polychlorinated biphenyls (PCBs), etc.	Annually
Total Trihalomethanes (TTHMs)	4	Bromoform, chloroform, etc.	Quarterly
Haloacetic acids (HAA5)	5	Monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, etc.	Quarterly
Lead and Copper	2	--	Annually
Per- and polyfluoroalkyl substances (PFAS)	25	Perfluorooctane Sulfonate (PFOS), Perfluorooctanoic Acid (PFOA), etc.	Semi-annually
Radiological Compounds	4	Gross alpha, uranium, radium 226/228, etc.	Every 4 years; sampled in CY 2023
Asbestos	1	--	Every 9 years; sampled in CY 2023

Table 2 lists the microbial contamination results for CY 2024. No microbial contaminants were detected in any drinking water samples.

Table 2. CY 2024 Biological Sampling Results

Contaminant	MCLG*	MCL*	Level Detected	Meet Standard?	Potential Source of Contaminant
Total Coliform	0	0 positive sample/ month	0 positive samples	Yes	Naturally present in environment
Fecal Coliform and E. coli	0	0 positive samples/ month	0 positive samples	Yes	Human or animal fecal waste

* See Appendix for explanation of terms and abbreviations

Table 3 lists all of the drinking water contaminants that were detected in CY 2024. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. For total trihalomethanes and haloacetic acids, compliance is based on the running average of all samples collected over a year. Therefore, if a single sample exceeds the MCL, but the average of all the readings for that year is less than the MCL, then the system is in compliance.

Table 3. CY 2024 Detected Water Contaminants

CONTAMINANTS	EPA		KEGS*	Your Water		Meet Standard?	Typical Source
	MCLG*	MCL*	MCL				
Inorganic Contaminants							
Barium in ppm	2	2	2	0.02		Yes	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Nitrate [measured as Nitrogen in ppm]	10	10	10	Low 1.9	High 2.9	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Total Nitrate and Nitrite in ppm	NR	NR	10	Low 1.9	High 2.9	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride in ppm	4	4	4	0.095		Yes	Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium in ppm	NR	NR	NR	11.0		Yes	Erosion of natural deposits
Total Trihalomethanes							
Total Trihalomethanes in ppb	NR	80 (annual average)	80 (annual average)	Low 18.5	High 54.6	Yes	By-product of drinking water chlorination
				Annual average			
				39.6			
Haloacetic Acids							
Haloacetic Acids in ppb	NR	60 (annual average)	60 (annual average)	Low 3.6	High 27.7	Yes	By-product of drinking water chlorination
				Annual average			
				19.5			

*See Appendix for explanation of terms and abbreviations. Bioenvironmental Engineering tested for Semi-Volatile Organic Chemicals and Volatile Organic Chemicals and detected none.

Table 4 lists the Lead and Copper results for CY 2024. The standard for lead and copper is that no more than 10% of samples exceed the action level. Lead and Copper monitoring for Osan Air Base has consistently met this requirement for the past 10 years.

Table 4. CY 2024 Lead and Copper Sample Results

Contaminant	EPA		KEGS*	# of sample sites exceeding action level	90th percentile value	Meet standard?	Potential Source of Contaminant
	MCLG*	AL*	AL*				
Lead in ppb	0	15	15	0 of 36 sites	4.22	<i>Yes</i>	Corrosion of household plumbing systems; erosion of natural deposits.
Copper in ppb	1300	1300	1300	0 of 36 sites	221.0	<i>Yes</i>	Corrosion of household plumbing systems; erosion of natural deposits.

*See Appendix for explanation of terms and abbreviations

Table 5 lists radiological contaminants results for CY 2023. The results presented in this report are from the most recent testing conducted in accordance with the KEGS: the monitoring frequency of radiological contaminants is every 4 years. The presence of regulated radiological contaminant in the water does not necessarily indicate that the water poses a health risk.

Table 5. CY 2023 Monitored Radiological Contaminants

Contaminant	EPA		KEGS* MCL	Your Water	Meet Standard?	Likely Source of Contaminant
	MCLG*	MCL*				
Gross Alpha in pCi/L	0	15	15	ND	<i>Yes</i>	Erosion of natural deposits
Combined Radium 226 and 228 in pCi/L	0	5	5	ND	<i>Yes</i>	Erosion of natural deposits
Uranium in ppb	0	30	30	ND	<i>Yes</i>	Erosion of natural deposits

*See Appendix for explanation of terms and abbreviations

Table 6 lists asbestos result for CY 2023. The result presented in this report is from the most recent testing conducted in accordance with the KEGS: the monitoring frequency of asbestos is every 9 years. The presence of regulated asbestos in the water does not necessarily indicate that the water poses a health risk.

Table 6. CY 2023 Detected Asbestos

Contaminant	EPA		KEGS MCL*	Your Water	Meet Standard?	Likely Source of Contaminant
	MCLG*	MCL*				
Asbestos MFL*	7	7	7	<0.1	<i>Yes</i>	Decay of asbestos cement water mains; Erosion of natural deposits

*See Appendix for explanation of terms and abbreviations

Table 7 lists the results of PFAS samples collected for CY 2024. The presence of the substances in the water does not necessarily indicate that the water poses a health risk.

Table 7. CY 2024 PFAS Compound

Contaminant	EPA	KEGS MCL	Your Water		Meet Standard?	Likely Source of Contaminant
	MCL		Low	High		
Perfluorooctanoic acid (PFOA) in ppt*	4.0	NR*	ND	ND	<i>Yes</i>	Component of aqueous film forming foam, a Firefighting foam
Perfluorooctanesulfonic acid (PFOS) in ppt*	4.0	NR*	ND	ND	<i>Yes</i>	Component of aqueous film forming foam, a Firefighting foam
Perfluorohexanesulfonic acid (PFHxS) in ppt*	10	NR*	ND	ND	<i>Yes</i>	Component of aqueous film forming foam, a Firefighting foam
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) in ppt*	10	NR*	ND	ND	<i>Yes</i>	Component of aqueous film forming foam, a Firefighting foam
Perfluorononanoic acid (PFNA) in ppt*	10	NR*	ND	ND	<i>Yes</i>	Component of aqueous film forming foam, a Firefighting foam
Perfluorobutanesulfonic acid (PFBS) in ppt*	n/a	NR*	ND	2.1	<i>Yes</i>	Component of aqueous film forming foam, a Firefighting foam
Mixture of two or more: PFHxS, PFNA, HFPO-DA, and PFBS	Hazard Index of 1 (unitless)	NR*	0	0	<i>Yes</i>	Component of aqueous film forming foam, a Firefighting foam

*See Appendix for explanation of terms and abbreviations

Where Can I Get More Information?

The Base Drinking Water Working Group (DWWG) meets every 6 months at building 752. If you have any specific questions or concerns about your drinking water, please contact the Osan Air Base Bioenvironmental Engineering (BE) office at 784-2623. BE can bring your questions or concerns to the DWWG and respond back to you. You can also contact the BE office for any additional information on drinking water or questions regarding this Consumer Confidence Report (CCR).

The Bioenvironmental Engineering Flight prepared this CCR and will post it on the Osan Air Base homepage (<http://www.osan.af.mil>).

Information about EPA water regulations can be found at <http://www.epa.gov>.

General information about Korean water sources in English and Korean can be found at <http://www.kwater.or.kr>.

APPENDIX

DEFINITIONS

Action Level (AL): The level of lead or copper which, if exceeded, triggers treatment or other requirements that a water system must follow.

Calendar Year (CY): The period from January 1 to December 31.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Non-detect (ND): The contaminant was not detected in the sample.

Not-Regulated (NR): The EPA and/or KEGS have not determined a regulatory limit for the contaminant in drinking water.

Safe Drinking Water Act (SDWA): The main federal law that ensures the quality of Americans' drinking water. Under SDWA, EPA sets standards for drinking water quality and oversees the states, localities, and water suppliers who implement those standards.

Units

MFL: million fibers per liter (a measure of asbestos in drinking water).

PCi/L: picocuries per liter (a measure of radioactivity).

Parts per billion (ppb): A ppb is a thousandth of a ppm.

Parts per million (ppm): Parts per million is the most commonly used term to describe minuscule amounts of contaminants in our environment. It is a measure of concentration that describes the amount of one material in a larger amount of another material. For example, the amount of a chemical in a volume of water. If you divide a liter of water into a million parts, then each part would be equal to "one part per million."

Parts per trillion (ppt): A ppt is a thousandth of a ppb.